

City of Cocoa Beach – Reclaimed Water ASR

Table I

Cycle	Injection		Storage	Recovery	
	Duration (days)	Rate (gpm)	Duration (days)	Duration (days)	Rate (gpm)
1	15	1,400	7	*	1,000
2	30	1,400	28	*	1,000
3	45	1,400	60	*	1,000

Note – During injection and recovery water will flow 24 hours per day.

Note – “\*” Water will be recovered from the ASR well until reclaimed water standards are exceeded.

gpm - gallons per minute